

HEBEI YUJINHONG TECHNOLOGY CO., LTD.

NO.368 Youyi North Street, Xinhua District, Shijiazhuang, Hebei 050000, China
Tel +86-311-68035766 · info@electricalsafetytools.com · www.electricalsafetytools.com



Natural Rubber Insulating Gloves 3 kV Working / 10 kV Test

Category: Insulating Gloves & PPE Product code: gloves-natural-rubber-3kv-10kv

Natural rubber insulating gloves for live working up to 3 kV, proof tested at 10 kV AC, made to GB/T 17622-2008 with a 370 mm length and an anti-slip palm texture.

SPECIFICATIONS

Working Voltage	3 kV
Test Voltage	10 kV AC
Material	Natural rubber
Length	370 mm ± 10 mm
Standard	GB/T 17622-2008
Surface	Smooth, anti-slip palm texture
Packaging	1 pair / vacuum-sealed bag
MOQ	10 pairs
Lead Time	10 days (1–10 pairs) / 20 days (11–1,000 pairs)
Place of Origin	Hebei, China

STANDARDS & CERTIFICATIONS

GB/T 17622-2008

PACKAGING & DELIVERY

MOQ	10 pairs
Packaging	1 pair per vacuum-sealed bag; single package 50 × 20 × 10 cm; gross weight 2.5 kg

PRODUCT VIEWS

